CATALOG NUMBER

ECLX068M



Ground Bar Kit

4 Position

Same As:

- LX068M
- LX068MU



GROUND BAR INSTALLATION INSTRUCTIONS



DANGER

Hazardous Voltage. Will cause death, serious injury or substantial property damage.

Turn off power supplying this equipment before working inside.

A SAFETY INSTRUCTIONS

Note: This instruction outlines the recommended installation procedure.

"LW" DEVICES - REMOVE FILLER SCREW FROM BACK OF BOX - SECURE GROUND BAR TO BACK OF BOX WITH NO. 10 SELF TAPPING SCREW PROVIDED. "LC" DEVICES - SECURE GROUND BAR TO BACK OF BOX WITH NO. 10 SELF TAPPING SCREW PROVIDED. \

(TOP)

SEE WIRING DIAGRAM FOR WIRE RANGE SIZE AND TIGHTENING TORQUE REQUIREMENTS.

© 2004 Copyright Siemens Energy & Automation, Inc.

4810455 Rev.A